

Attention Landscape Maintenance Staff:

Subject: Lateral isolation valves on this Golf Course

This Golf Course is equipped with **PVC Slo-Close Ball Valves** on the laterals. Slo-Close valves provide the positive shut-off of a ball valve, and complete corrosion resistance. The rotation of the operating nut provides slow closure which greatly reduces the opportunity for water hammer.

These valves require only one (1) turn counter-clockwise to open, one turn clockwise to close.

The turning cycle time (for one rotation of the operating nut) should be:

5 – 10 seconds to open
3 – 5 seconds to close

- Do not try to turn past the stops.
- Do not attempt to throttle with this valve in the partially open or closed position.

Use a standard sprinkler key wrench to operate the nut.

If you have any questions regarding the operation or maintenance of this valve, please contact:

Colonial Engineering, Inc.
6400 Corporate Avenue
Portage, MI 49002
PH: In USA Toll Free 1-866-879-5982, Ext 3114
All others, 1-269-323-2495, Ext 3114.

